

# Loxahatchee River District

Water Reclamation | Environmental Education | River Restoration

2500 Jupiter Park Drive, Jupiter, Florida 33458-8964

Telephone (561) 747-5700 • Fax (561) 747-9929 • [www.loxahatcheeriver.org](http://www.loxahatcheeriver.org)

D. Albrey Arrington, Ph.D., Executive Director



## MEMORANDUM

TO: D. ALBREY ARRINGTON, Ph.D.  
Executive Director

FROM: CLINTON R. YERKES  
Deputy Executive Director

DATE: JANUARY 6, 2015

SUBJECT: LIFT STATION #114 (Bluffs-Marcinski Rd.)  
Pump Purchases

---

Lift Station #114 is a large, 3 pump, submersible lift station located at the west end of Marcinski Rd.

This station is undergoing significant rehabilitation and re-evaluation of its function in the system to improve efficiency. Along with the pump replacement which is needed more expeditiously, the station will be receiving a new control panel at a future date.

The District has obtained competitively bid pricing by “piggy-backing” on a contract from Orange County, Florida, serving the Orlando area.

The following motion is suggested for approval of this purchase:

**“THAT THE DISTRICT GOVERNING BOARD authorize award of contract to Xylem Water Solutions USA, Inc. for the purchase of 2 Flygt Model NP-3171.185, 25 h.p. submersible pumps in accordance with Quote #2014-WEP-0913, in the amount of \$36,037.30.”**

Should you have any questions please contact me or Tom Vaughn.

Gordon M. Boggie  
Board Member

Stephen B. Rockoff  
Board Member

Dr. Matt H. Rostock  
Chairman

Harvey M. Silverman  
Board Member

James D. Snyder  
Board Member



**Xylem Water Solutions USA, Inc.**  
**Flygt Products**

December 19, 2014

LOXAHATCHEE RIVER DIST  
2500 JUPITER PARK DRIVE  
ATTN: ADRIAN  
JUPITER FL 33458-8964

1730 Tenth Street W  
Riviera Beach, FL 33404  
Tel (561) 848-1200  
Fax (561) 848-1299

Quote # 2014-WEP-0913

**Re: NEW PUMP QUOTE – (REF ORANGE COUNTY CONTRACT PRICING)**

Xylem Water Solutions USA Inc. is pleased to offer for the following equipment.

**EQUIPMENT**

Qty	Description	Extended Price
2	Flygt Model NP-3171.185 6" volute Submersible pump equipped with a 460 Volt / 3 phase / 60 Hz 25 HP 1750 RPM motor, 435 impeller, 1 x 50 Ft. length of submersible cable, FLS leakage detector, volute is prepared for Flush Valve, SB3	\$ 36,037.30

**Total Project Price \$ 36,037.30**

**Incoterm:** 1 FCA - Free Carrier **Named Placed:** 02 - US WH/ Factory

Incoterms 2010 clarify responsibility for costs, risks, & tasks associated with the shipment of goods to the named place.

Taxes: The prices quoted above do not include any state, federal, or local sales tax or use taxes. Any such taxes as applicable must be added to the quoted prices.

Terms of delivery: Freight PP/Line Item

Terms of Payment: Net 45 Days

Terms & Conditions:

Order is subject to credit approval.

A charge of 1.5% per month will be added to all balances unpaid 45 days after invoice date.

A cancellation charge of 20% of the value of the order will be assessed for special orders or control panels cancelled after production is completed.

Sincerely,

Brian Stengle  
Sales Representative  
(561) 515-8708  
brian.stengle@xylem-inc.com

Company Name: \_\_\_\_\_

Accepted By: \_\_\_\_\_

Print Name: \_\_\_\_\_

Date: \_\_\_\_\_

